

Voltage 0: 54.76V	Range 0: 342mV	Voltage 1: 54.85V	Range 1: 44mV	Voltage 2: 54.67V	Range 2: 55mV	Voltage 3: 54.69V	Range 3: 150mV	Voltage 4: 54.69V	Range 4: 196mV	O.O.S errors: 519	CRC Errors: 517
--------------------------	-----------------------	--------------------------	----------------------	--------------------------	----------------------	--------------------------	-----------------------	--------------------------	-----------------------	--------------------------	------------------------

Modules

Bank	Module	Voltage	V. Min	V. Max	Temp Int °C	Temp Ext °C	Bypass PWM %	Bad packet count	Packets received	Balance energy used (mAh)	Identify	Configure
0	0	3.857	3.857	3.857	10	10		0	1545	0	Identify	Configure
0	1	3.885	3.884	3.888	10	10		0	1545	0	Identify	Configure
0	2	3.882	3.882	3.882	10	10		0	1545	0	Identify	Configure
0	3	3.892	3.890	3.892	11	10		0	1545	0	Identify	Configure
0	4	3.890	3.888	3.892	11	11		0	1545	0	Identify	Configure
0	5	3.882	3.881	3.882	11	11		0	1545	0	Identify	Configure
0	6	3.889	3.889	3.889	11	11		0	1545	0	Identify	Configure
0	7	3.885	3.884	3.885	11	11		0	1545	0	Identify	Configure
0	8	3.889	3.889	3.890	11	11		0	1545	0	Identify	Configure
0	9	3.889	3.889	3.891	11	11		0	1545	0	Identify	Configure
0	10	3.917	3.916	3.917	11	11		0	1545	0	Identify	Configure
0	11	3.895	3.894	3.896	11	11		0	1545	0	Identify	Configure
0	12	4.199	3.773	4.205	11	11		517	1349	0	Identify	Configure
0	13	3.913	3.912	3.914	11	11		517	1349	0	Identify	Configure
1	14	3.921	3.921	3.921	10	10		517	1349	0	Identify	Configure
1	15	3.920	3.920	3.921	10	10		517	1349	0	Identify	Configure
1	16	3.939	3.930	3.939	10	10		499	1362	0	Identify	Configure
1	17	3.943	3.919	3.944	10	10		499	1362	0	Identify	Configure
1	18	3.904	3.899	3.906	11	11		499	1362	0	Identify	Configure
1	19	3.917	3.917	3.918	11	11		499	1362	0	Identify	Configure
1	20	3.908	3.907	3.909	11	11		499	1362	0	Identify	Configure